

JOB INFORMATION

Reference / Job#: ME56
Installation address: 215 Goatley Rd, Warkworth, 0981

CUSTOMER INFORMATION

Name: Mark Dashper **Email:** mark@dashper.net.nz **Phone:** 09 422335
Postal address: 215 Goatley Rd, Warkworth, 0981 **Mobile:**

ELECTRICAL WORKER INFORMATION

Name: John Lepper **Registration:** E245568
Company Name: Mahurangi Electrical **Phone:**
Email: John@mahurangielectrical.co.nz

WORK DETAILS

Date Started: 13/04/2017 **Date Completed:** 20/07/2017 **Work Risk:** High Risk
Type of System: 230/400v MEN **Type of Work:** New Work
Work has been done in accordance with: Part 2 of AS/NZS 3000

DESCRIPTION OF WORK DONE

New Underground Main Supplying 3 plynths for 6 house lots. 3 phase 100 Amp supply to 60 A single phase connection points.

CERTIFICATION OF WORK

I certify that the completed prescribed electrical work to which this Certificate of Compliance applies, has been done lawfully and safely and the information in the certificate is correct in that the installation, or part of the installation:

Has been installed in accordance with a certified design *	
Has an earthing system that is correctly rated	
Contains fittings which are safe to connect to a power supply	✓
Relies on supplier's Declaration of Conformity *	✓
Relies on manufacturer's instructions *	✓
Has been satisfactorily tested in accordance with Electrical (Safety) Regulations 2010	✓
All parts of the installation are safe to connect to a power supply list, if NOT, please detail what parts ARE safe to connect	✓

* References, where applicable, can be found on the additional information sheet.

**Certified Worker's
Signature**



Date: 26/07/2017



This is an important document and should be retained for a minimum of seven years.

Version 3.01

